

# BUTLER AREA SEWER AUTHORITY

100 LITMAN ROAD • BUTLER, PA 16001-3256

(724) 282-1978 • FAX (724) 282-7656

www.basapa.org

**GERALD S. PATTERSON, JR.**  
CHAIRMAN

**CYNTHIA S. McKNIGHT**  
VICE CHAIRMAN

**PAUL F. SYBERT**  
SECRETARY

**KENNETH L. HENRY**  
TREASURER

**EDGAR E. HASSLER, JR.**  
ASSISTANT SECRETARY  
AND TREASURER

**DUANE E. McKEE**  
EXECUTIVE DIRECTOR

**M. JOHN SCHON, P.E.**  
OPERATIONS DIRECTOR

**RONATA L. LAVORINI, CPA**  
FINANCE DIRECTOR

**DANIEL SLOMERS, P.E.**  
AUTHORITY ENGINEER

**DILLON McCANDLESS KING  
COULTER & GRAHAM**  
SOLICITOR

## BUTLER AREA SEWER AUTHORITY RESOLUTION NO. 11-10-2020-02

**AMENDMENT TO THE WASTEWATER DISCHARGE LIMITATIONS (LOCAL LIMITS) CONTAINED IN CHAPTER 400 INDUSTRIAL SEWER USE, ARTICLE III REGULATION OF WASTEWATER DISCHARGES OF THE AUTHORITY'S CODIFIED RULES AND REGULATIONS GOVERNING INDUSTRIAL SEWER USE, REVISED MARCH 11, 2014.**

WHEREAS, the Butler Area Sewer Authority completed a Local Limits Reevaluation in accordance with the conditions of NPDES Permit No. PA0026697, which was issued by the Pennsylvania Department of Environmental Protection (DEP) on August 9, 2018, and became effective on September 1, 2018; and

WHEREAS, this Local Limits Reevaluation, dated February 2020, was submitted to the U. S. Environmental Protection Agency (EPA), the Pretreatment Program Approval Authority for Pennsylvania, and was subsequently revised on July 15, 2020 and September 28, 2020, per the recommendations of the EPA, and

WHEREAS, the EPA approved this Local Limits Reevaluation and the Authority's Proposed Maximum Daily Discharge Concentration Limits shown in the attached Table 1 on October 27, 2020, and

WHEREAS, the Authority also wishes to amend Chapter 400 Industrial Sewer Use, Article III Regulation of Wastewater Discharges, Section 400-3.02 Specific Prohibitions, Paragraph (O) of the Authority's Codified Rules and Regulations to read as follows: "Any wastewater containing fats, oils, and/or grease (FOG) of animal or vegetable origin in concentrations greater than 100 mg/L as defined by EPA Test Method 1664A or in amounts that will cause Interference or Pass Through."


NOW, THEREFORE, BE IT RESOLVED that the Butler Area Sewer Authority hereby amends Chapter 400 Industrial Sewer Use, Article III Regulation of Wastewater Discharges, Section 400-3.02 Specific Prohibitions, Paragraph (O) as noted above and amends Chapter 400 Industrial Sewer Use, Article III Regulation of Wastewater Discharges, Section 400-3.07, Table 1 of the Authority's Codified Rules and Regulations to delete the existing Maximum Daily Discharge Concentration Limits and to adopt the Proposed Maximum Daily Discharge Concentration Limits shown in the attached Table 1 effective January 1, 2021.

**BUTLER AREA SEWER AUTHORITY**  
**RESOLUTION NO. 11-10-2020-02**  
**(Continued)**

RESOLVED, this 10th day of November 2020 by roll-call vote of the Board of Directors of the Butler Area Sewer Authority at a duly advertised meeting.

ATTEST:

BUTLER AREA SEWER AUTHORITY

  
\_\_\_\_\_  
Paul F. Sybert, Secretary

By:   
\_\_\_\_\_  
Gerald S. Patterson, Jr., Chairman

**TABLE 1  
SPECIFIC WASTEWATER DISCHARGE LIMITATIONS  
(APPROVED BY EPA ON 10/27/2020)**

PARAMETER	EXISTING MAXIMUM DAILY DISCHARGE CONCENTRATION (mg/L) *	REVISED MAXIMUM DAILY DISCHARGE CONCENTRATION (mg/L) *
Arsenic (Total)	0.53	0.25
Cadmium (Total)	0.05	0.05
Chromium (Total)	1.12	2.0
Copper (Total)	1.25	1.84
Lead (Total)	0.52	0.5
Mercury (Total)	0.0002 #	0.0002 #
Molybdenum (Total)	1.82	1.5
Nickel (Total)	6.84	6.5
Selenium (Total)	0.26	0.25
Silver (Total)	1.37	1.0
Zinc (Total)	2.02	3.17
Cyanide (Total)	0.07	0.01
Ammonia-Nitrogen	None	30

\* Based on composite sample of discharge over any one day or normal discharge period if less than 24 hours.

# Not Detectable Using EPA Test Method 245.1.